

Listings

PT. ETI FIRE SYSTEMS	LISTING DATE & REFERENCE	DESCRIPTION
Submitted 16 January 2009 Listed April 2009 302-0109-005		Fire Test for ETI engineered fire system. Design reviewed to NFPA 11. Fire Test using 7.5 square meter scenario, protected by 10 nozzle and 35 liters of agent Result : 1. DIRECT EXTINGUISHMENT 8 SECONDS 2. INDERECT EXTINGUISHMENT 48 SECONDS All components listed as defined in Technical Manual 5
Submitted 16 Jan 2009 Listed April 2009 302-0109-006		Verification of cylinder vessel design requirements. Design compliance to AS 2470-2005
March 2010 302-0310-001		The ETI Engineered Fire Suppression System as defined in the sixth edition Technical Manual listed here in as compliant to AS 5062 - As an Engineered Foam Fire Suppression System